



PUBLIC WORKS DEPARTMENT (B & R), HARYANA

Office of Executive Engineer,
Provincial Division,
PWD B&R Br., Faridabad.
Tele – 0129-2288187



Memo No. 2229

Dated 26/3/2024

pwd-eepd1-faridabad@hry.nic.in

To

The Principal,
St. Albans School,
Sector-15 Faridabad.

Subject:- NOC for building safety certificate for St. Albans School in Sector-15 district Faridabad.

Reference:- Your office letter dated 08.02.2024.

In the connection of above cited subject, it is submitted that the above said school building is inspected by the Sub Divisional Engineer, Provincial Sub Division No.3, PWD B&R Br., Faridabad along with concerned Junior Engineer on 13.03.2024. The school building is having ground floor, first floor, second floor & third floor. The inspection fees of site is deposited by the applicant vide GRN No.0114010028 dated 12.03.2024. Following are the features of the building observed during the inspection of the school:-

GROUND FLOOR:-

➤ At ground floor there are 01 no. Admin block, 01 no. Staff room, 01 no. Seminar hall, 10 no. classrooms, 01 no. Medical room, 01 no. Staff office, 01 no. Head Mistress office, 03 no. toilets, 02 no. staircase, 01 no. MS staircase upto first floor only exist in the school premises.

FIRST FLOOR:-

➤ At first floor level there are 14 no. classrooms, 01 no. Staff room, 01 no. Counseling room, 01 no. Science Lab, 01 no. computer lab, 02 no. staircase, 03 no. toilet, exist in the school premises.

SECOND FLOOR:-

➤ At second floor there are 11 no. classrooms, 01 no. dance room, 01 no. SST Lab, 01 no. path lab, 01 no. Library, 01 no coordinator office, 03 no. toilets and 02 no. staircases exist in the school premises.


THIRD FLOOR:-

➤ At second floor there are 09 no. classrooms, 01 no. toilets, 02 no. Sports room and 02 no. staircases exist in the school premises.

The building is having frame structure with R.C.C. columns, R.C.C. beams, R.C.C. slab & 9" thick brick wall on outer face. The structure stability certificate has been also enclosed, which issued by Rakesh Bhatia & Associates, Office-cum-Resi. 1- D/129, NIT, Faridabad on dated 20.06.2019. The fire NOC has been issued by the Assistant Divisional Fire Officer / Fire Station Officer, Fire Station, Sector-15A, Faridabad memo No.FS/2022/941 dated 15.12.2022 valid upto 14.12.2025. The hygiene certificate is also issued by O/o Civil Surgeon, Faridabad vide office No. HHC/Fbd/2023-24/163 dated 11.05.2023 valid upto 31.03.2024. Some alternations have been done by the school authorities like 01 no staircase shown in the drawings submitted by them but no staircase found at the site and lift exists at the site but not shown in drawings.

Keeping in view all the circumstances and the documents submitted by the applicant, the building seems to be safe. The periodical inspection of the school building must be ensured.

DA/Nil



Executive Engineer,
Provincial Division,
PWD B&R Br Faridabad.


Endst.No.

Dated:-

Copy of above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.3, PWD B&R Br., Faridabad for information and necessary with reference to his office Memo No. 886 dated 18.03.2024.

DA/Nil


Executive Engineer,
Provincial Division,
PWD B&R Br., Faridabad


Headmistress
St. Albans School
Sector-15, Faridabad